

CONECTOR KEYSTONE – RJ45 CAT.6 – 90°/180° – UTP – 1.0 - DECLARACIÓN DE CUMPLIMIENTO

Publicado en 27-06-2024 por barpaadminuser



Compliance Statement

No. 2025-455

Unscreened Permanent Link, Class E

Company

barpa
Rua Noé Pereira, 473
4510-706 Gondomar
Portugal

Permanent Link Identification (2 connector model)

Horizontal cable:

barpa Cable Cat.6 U/UTP LSZH
Part no. 82222122MMM (M – of Meters)

RJ45 connector for telecommunications outlet and patch panel:

Keystone Jack RJ45 UTP Cat.6 Keystone; Part no. 8224211C180 (C: Colour)
Keystone Jack RJ45 UTP Cat.6 Keystone 90 degrees; Part no. 8224211C090 (C: Colour)

Including use with (mounting fixtures):

Patch panel: barpa Empty Patch Panel 1U 24P; Part no. 82230101124

Wall outlet: barpa Faceplate 45x45 for RJ45 keystone jack; Part no: 822501T000D
(T: Type, D: number of doors)

Generic cabling standards - Class E Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12527305-01, DANAK-19/25107

EC Cabling product ID

7377

CS valid until

1 September 2026

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 5 August 2025

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager



FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com

